



INTERNATIONAL STANDARD ISO 11064-3:1999
TECHNICAL CORRIGENDUM 1

Published 2002-02-01

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Ergonomic design of control centres —

Part 3: Control room layout

TECHNICAL CORRIGENDUM 1

Conception ergonomique des centres de commande —

Partie 3: Agencement de la salle de commande

RECTIFICATIF TECHNIQUE 1

Technical Corrigendum 1 to International Standard ISO 11064-3:1999 was prepared by Technical Committee ISO/TC 159, *Ergonomics*, Subcommittee SC 4, *Ergonomics of human-system interaction*.

Page 11

Figure 5

In the key, replace the text for *c* and *d* with the following:

c 500 = clearance under the luminaire

d 2 000 = body height, including clothing allowance

Pour plus d'infos, merci de nous contacter.

Association Sénégalaise de Normalisation

4 Avenue Jean Jaurès, Immeuble El Hadj Omar DIA, 6 ème Etage
Dakar - SENEGAL

Tel: +221 33 829 58 25

Email: asn@asn.sn